Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FP258

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LUTZEN, RAYMOND	Phone #: (715)879-5435
Mailing Address: E9480 CTY HWY E	
City: ELK MOUND	State: WI — Zip Code: 54739
County: Dunn	Co. Permit #: — Notification #: — Completed: 12-08-1996
Well Constructor (Business Name): WATER WELL SPECIALISTS	Lic. #: 6070 — Facility ID # (Public Wells):
Address: 3701 ROBIN RD, EAU CLAIRE WI 54703	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.9

1. Well Location

Town of SPRING BROOK				Fire # (if avail.): E9480
Street Address or Road Name and Number: E9480 CTY HWY E				
Subdivision Name:			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
NE NW or Govt Lot #:	Section: 23	Township: 27 N	Range: 11 W	

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: NEW CONSTRUCTION
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
7	Surface	10
6	10	139.5

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	G	SAND GRAVEL COBBLES	Surface	79
		Y	C	SAND GRAVEL W CLAY	79	121
		Y		SAND GRAVEL	121	139.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL ASTM A53 B 18 97 LBS PE DIRVE SHOE 4 BY 65 PACKER	Surface	136
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS JOHNSON 018 IN SLOT	135	139.5

7. Grout or Other Sealing Material

Method MOUNDED IN STARTE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GRANULAR	Surface	0	

9. Static Water Level
100 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 18 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAW		12-08-1996
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		141
Building Drain - Sanitary		53
Building Overhang		12
Sewer - Building Sanitary		53
Septic or Holding, or POWTS Tank		59

Comment:

Created On: 03-03-1997 Updated On: 05-24-2016 Review Status: