Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FP980

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VOLLBRECHT, RUSSEL	Phone #: (715)877-2719
Mailing Address: RR 2 BOX 160	
City: FALL CREEK	State: WI — Zip Code: 54742
County: Eau Claire	Co. Permit #: W08959 — Notification #: — Completed: 11-10-1993
Well Constructor (Business Name): VERN PEAK	Lic. #: 14 — Facility ID # (Public Wells):
Address: RT 3 BOX 215, CADOTT WI 54727-9114	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.7

1. Well Location

Town of LUDINGTON	Fire # (if avail.): 2187
Street Address or Road Name and Number: COUNTY RD D	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:

NE	NE	Section	Township	Range
or Govt Lot #		13	27 N	7 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NON POTABLE LIVESTOCK @ 2

Construction Type: Drilled

3. Well serves 0 # of LIVESTOCK

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	30
6	30	97

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	H	CLAY @ SHALE	Surface	9
		N		SANDROCK	9	97

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A53B U.S. SAWHILL P.E. WELDED	Surface	32
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

63 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	30	5 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
VP		11-10-1993
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	10	Silo/Storage Tube	>	180
Animal Barn Pen	>	115	Barn Gutter	>	120

Comment:

Created On: 02-02-1994 Updated On: 02-02-1994 Review Status: