

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FP981		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner GREENWOOD, SCOTT						Phone # (715)289-3373		1. Well Location				Fire # (if avail.)					
Mailing Address RR 2 BOX 222						Town of SIGEL						Street Address or Road Name and Number					
City CADOTT				State WI		Zip Code 54727		COUNTY TRUNK X				Subdivision Name		Lot #		Block #	
County Chippewa		Co. Permit # W09084		Notification #		Completed 11-18-1993		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Well Constructor (Business Name) VERN PEAK				Lic. # 14		Facility ID # (Public Wells)		°N °W				NE SW Section Township Range or Govt Lot # 1 28 N 7 W					
Address RT 3 BOX 215 CADOTT WI 54727-9114				Well Plan Approval #		Approval Date (mm-dd-yyyy)		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 3.1		Reason for replaced or reconstructed well ?		NEW HOME				Construction Type Drilled					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Heat Exchange ___ # of drillholes				Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		37		Rotary - Mud Circulation				S F		SAND FILL MATERIAL		Surface		5	
6		37		60.5		<u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)				C H		CLAY @ SHALE		5		10	
										N		SANDROCK		10		60.5	
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is			
6		STEEL 18.97 A53B U.S. SAWHILL P.E. WELDED				Surface		38		26 ft. below ground surface				24 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes			
										Pumping level 30 ft. below surface				Disinfected ? Yes			
										Pumping at 12.2 GP M for ____ Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method PRESSURE GROUT												Filled & Sealed Well(s) as needed?					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT GROUT		Surface		38		7 S		VP						11-18-1993			
								Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 02-02-1994

Updated On: 02-02-1994

Review Status: