Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FP981

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GREENWOOD, SCOTT			Phone #: (715)289-3373
Mailing Address: RR 2 BOX 222			
City: CADOTT	State: WI	Zip Code: 54727	
County: Chippewa	Co. Permit #: W09084	Notification #	Completed: 11-18-1993

1. Well Location

Town of SIGEL

Fire # (if avail.)

Street Address or Road Name and Number: COUNTY TRUNK X

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
VERN PEAK	14	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

Well Plan Approval #

NE	SW	Section	Township	Range
or Govt Lot #		1	28 N	7 W

Address: RT 3 BOX 215
CADOTT WI 54727-9114

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		3.1

Reason for replaced or reconstructed well ?

NEW HOME

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	37
6	37	60.5

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	F	SAND FILL MATERIAL	Surface	5
		C	H	CLAY @ SHALE	5	10
		N		SANDROCK	10	60.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A53B U.S. SAWHILL P.E. WELDED	Surface	38
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 12.2 GP M for _____ Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: PRESSURE GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	38	7 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
VP		11-18-1993
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank	>	60

Comment:

Created On: 02-02-1994 Updated On: 02-02-1994 Review Status: