Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FQ289

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MANNIE, TIMOTHY			Phone #: (715)485-3092
Mailing Address: 1318 KARAH PARK TRL			
City: BALSAM LAKE	State: WI	Zip Code: 54810	
County: Polk	Co. Permit #:	Notification #:	Completed: 10-26-1995

1. Well Location

Town of MILTOWN

Fire # (if avail.):

Street Address or Road Name and Number: 1378 KAMAH

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LYLE C SULLIVAN	120	

Latitude / Longitude in Decimal Degree (DD): 45.47 °N -92.4461 °W

Method Code: GCD013

SW	SW	Section	Township	Range
or Govt Lot #		35	35 N	17 W

Well Plan Approval #:

Address: 1467 300TH AVE
FREDERIC WI 54837-9593

Approval Date (mm-dd-yyyy):

2. Well Type Reconstruction

of previous unique well # HQ353 constructed in 95

Hicap Permanent Well #	Common Well #	Specific Capacity

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole	Lower Open Bedrock
Rotary - Mud Circulation	
Rotary - Air	
Rotary - Air & Foam	
Drill-Through Casing Hammer	
Reverse Rotary	
Cable-tool Bit ____in. dia...	
Dual Rotary	
Temp. Outer Casing ____in. dia	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	31.66

6. Casing, Liner, Screen — Removed? ____depth ft. (If NO explain on back side)

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	A53 USA STEEL	Surface	27.66
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	STAINLESS STEEL 12 SLOT	27.66	31.66

9. Static Water Level

5.6 ft. below ground surface

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

10. Pump Test

Pumping level _____ ft. below surface

Pumping at 8 GP M for 2 Hrs.

Pumping Method ?

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
LCS		10-26-1995
Drill Rig Operator	Lic or Reg #	Date Signed
		10-26-1995

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		6	Shoreline/Pool		65
			Septic or Holding, or POWTS Tank		45

Comment: NON SENT 090195 REGARDING CASING LESS THAN 25'. WELL WAS RECONSTRUCTED DRIVING PIPE 5'8" DEEPER.

Created On: 12-04-1995 Updated On: 06-30-2020 Review Status: