Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FR161

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETTERS, FRED			Phone #: (920)459-7159
Mailing Address: 3645 S 18TH ST			
City: SHEBOYGAN	State: WI	Zip Code: 53081	
County: Oneida	Co. Permit #:	Notification #:	Completed: 08-18-1999

Well Constructor (Business Name): RUDYS CONTRACTING INC	Lic. #: 4403	Facility ID # (Public Wells):	
Address: 5111 W SHERMAN ST WAUSAU WI 54401-9315		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of MINOCQUA
Street Address or Road Name and Number

Fire # (if avail.)

Subdivision Name		Lot #: 4	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

NE	NW	Section	Township	Range
or Govt Lot # 004		9	39 N	6 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	82

Upper Enlarged Drillhole
Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	40
		C	S	SANDY CLAY	40	72
		Y		SAND & GRAVEL	72	82

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM A53 WELDED 18.97 LBS SAWHILL USA	Surface	79
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	JOHNSON 10	79	82

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
13 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NEW CONSTRUCTION

13. Constructor / Supervisory Driller	Lic #	Date Signed
FS		08-24-1999
Drill Rig Operator	Lic or Reg #	Date Signed
FS		08-24-1999

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		22
Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 10-18-1999 Updated On: 10-18-1999 Review Status: