

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FR161		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner PETTERS, FRED						Phone # (920)459-7159		1. Well Location				Fire # (if avail.)		
Mailing Address 3645 S 18TH ST						Town of MINOCQUA						Street Address or Road Name and Number		
City SHEBOYGAN				State WI		Zip Code 53081								
County Oneida		Co. Permit #		Notification #		Completed 08-18-1999		Subdivision Name			Lot # 4		Block #	
Well Constructor (Business Name) RUDYS CONTRACTING INC				Lic. # 4403		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address 5111 W SHERMAN ST WAUSAU WI 54401-9315				Well Plan Approval #		NE NW		Section 004		Township 39 N		Range 6 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Range		Range				
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?								
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		82		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
S				SAND				Surface		40				
C S				SANDY CLAY				40		72				
Y				SAND & GRAVEL				72		82				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		NEW BLK ASTM A53 WELDED 18.97 LBS SAWHILL USA				Surface		79						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		JOHNSON 10				79		82						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
				Surface										
9. Static Water Level														
13 ft. below ground surface														
10. Pump Test														
Pumping level 20 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?														
11. Well Is														
14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? No NEW CONSTRUCTION														
13. Constructor / Supervisory Driller														
FS														
Date Signed 08-24-1999														
Drill Rig Operator														
FS														
Date Signed 08-24-1999														

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		22
			Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 10-18-1999

Updated On: 10-18-1999

Review Status: