Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FR165

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KNUTSON, TOM	Phone #: (608)825-3486
Mailing Address: 731 N BROADWAY DR	
City: SUN PRAIRIE	State: WI — Zip Code: 53590
County: Oneida	Co. Permit #: — Notification #: — Completed: 08-19-1999
Well Constructor (Business Name): RUDYS CONTRACTING INC	Lic. #: 4403 — Facility ID # (Public Wells):
Address: 5111 W SHERMAN ST WAUSAU WI 54401-9315	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 7.5

1. Well Location

Town of LK TOMAHAWK

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

or Govt Lot #	Section	Township	Range
SE SE	34	39 N	7 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND & GRAVEL	Surface	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM A53 WELDED 18.97# SAWHILL USA	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	JOHNSON 10	37	40

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 24 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NEW CONSTRUCTION

13. Constructor / Supervisory Driller	Lic #	Date Signed
FS		11-29-1999
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RZ		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		16
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 03-05-2001 Updated On: 03-05-2001 Review Status: