

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FR166		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner RYSKIEWICZ, EUGENE						Phone # (715)693-3563		1. Well Location				Fire # (if avail.)	
Mailing Address 505 WILLOW ST						Town of LK TOMAHAWK						6934	
City MOSINEE						State WI		Zip Code 54455				Street Address or Road Name and Number HIDEOUT LN	
County Oneida		Co. Permit #		Notification #		Completed 08-18-1999		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) RUDYS CONTRACTING INC				Lic. # 4403		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.8002 °N -89.5985 °W				Method Code GCD013	
Address 5111 W SHERMAN ST WAUSAU WI 54401-9315				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 10 38 N 7 E		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Property ? No		Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock							
6		Surface		100		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S		SAND				Surface		65					
X		SAND & CLAY MIX				65		90					
Y		SAND & GRAVEL				90		100					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW BLK ASTM A53 WELDED 18.97 LBS SAWHILL USA				Surface		97					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
5		JOHNSON 10				97		100					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NA				Surface									
9. Static Water Level													
62 ft. below ground surface													
10. Pump Test													
Pumping level 69 ft. below surface													
Pumping at 15 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
16 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No													
NEW CONSTRUCTION													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
FS										08-19-1999			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Building Overhang		8
			Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 10-03-2000

Updated On: 06-30-2020

Review Status: