Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FR166

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RYSKIEWICZ, EUGENE			Phone #: (715)693-3563
Mailing Address: 505 WILLOW ST			
City: MOSINEE	State: WI	Zip Code: 54455	
County: Oneida	Co. Permit #:	Notification #:	Completed: 08-18-1999

Well Constructor (Business Name): RUDYS CONTRACTING INC	Lic. #: 4403	Facility ID # (Public Wells):
Address: 5111 W SHERMAN ST WAUSAU WI 54401-9315		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.1

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LK TOMAHAWK

Fire # (if avail.): 6934

Street Address or Road Name and Number: HIDEOUT LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.8002 °N	-89.5985 °W			GCD013
SW NE or Govt Lot #	Section: 10	Township: 38 N	Range: 7 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	65
X	SAND & CLAY MIX	65	90
Y	SAND & GRAVEL	90	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM A53 WELDED 18.97 LBS SAWHILL USA	Surface	97
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	JOHNSON 10	97	100

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NA	Surface		

9. Static Water Level
62 ft. below ground surface

10. Pump Test
Pumping level 69 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NEW CONSTRUCTION

13. Constructor / Supervisory Driller	Lic #	Date Signed
FS		08-19-1999
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60

Type	Qualifier	Distance
Building Overhang		8
Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 10-03-2000 Updated On: 06-30-2020 Review Status: