Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FT130

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SHARON BENDER	Phone #: (414)693-8167
Mailing Address: W2323 COUNTY LINE RD	
City: CLEVELAND	State: WI — Zip Code: 53015
County: Sheboygan	Co. Permit #: — Notification #: — Completed: 05-15-1992
Well Constructor (Business Name): WEBER, ROGER	Lic. #: 99 — Facility ID # (Public Wells):
Address: W2691 ST CHARLES RD CHILTON WI 53014-9624	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of HERMAN

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE NW or Govt Lot #: — Section: 1 — Township: 16 N — Range: 22 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

GETTING WATER FROM NEIGHB

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	121

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	2
R		C		RED CLAY	2	35
		S		SAND	35	49
		C	G	STONEY CLAY	49	118
	W	G		WATER BEARING GRAVEL	118	121

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STAND. STEEL PIPE-NEW 18.97#/FT. P.E.SEAMLESS LTV STEEL ASTM-A-53 GR. B	Surface	121
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 73 ft. below surface

Pumping at 20 GP for 3 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW		05-15-1992
Drill Rig Operator	Lic or Reg #	Date Signed
FF		05-15-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65
Building Overhang		20

Type	Qualifier	Distance
Sewer - Building Sanitary		35
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: