Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FW311

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NORDER, AARON	Phone #: (608)329-7966
Mailing Address: 2313 15TH AVE	
City: MONROE	State: WI — Zip Code: 53566
County: Green	Co. Permit #:
Notification #	Completed: 09-30-1994
Well Constructor (Business Name): NIFFENEGGER, ED JR	Lic. #: 135
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 902 2ND ST MONROE WI 53566	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #	Common Well #
Specific Capacity: 2.2	

1. Well Location

Town of SYLVESTER	Fire # (if avail.): W4029
Street Address or Road Name and Number: CO FF	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 42.6664 °N -89.5613 °W	Method Code: GCD013
NW NW or Govt Lot #	Section: 9 — Township: 2 N — Range: 8 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: WATER FOR NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	62
6	62	160

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Air ..... — No

Rotary - Mud Circulation .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	1
-	B	L	-	BROKEN LIMESTONE	1	4
Y	-	L	-	BUFF GALENA LIMESTONE	4	25
U	-	L	-	BLUE LIMESTONE	25	135
-	-	N	-	ST. PETER SANDSTONE	135	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD. WT. ST..280 WALL 18.97# PER FT. PL END-WELDED JTS. USA SAWHILL A53B ASTM	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

105.5 ft. below ground surface

10. Pump Test

Pumping level 110 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	62	15 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
RN		11-20-1994
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	90	Building Overhang		10
			Septic or Holding, or POWTS Tank	>	30

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	WCR Submit Time	09/30/1994	REC'D WCR 1/21/14 W/NOTE: SANDY, FOUND THIS LOG TODAY IN OUR FILES. RANDY SAID TO SEND IT TO YOU.

Created On: 02-03-2014 Updated On: 01-21-2020 Review Status: