

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FW311		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner NORDER, AARON						Phone # (608)329-7966		1. Well Location				Fire # (if avail.)	
Mailing Address 2313 15TH AVE						Town of SYLVESTER						W4029	
City MONROE						State WI		Zip Code 53566				Street Address or Road Name and Number	
County Green						Co. Permit #		Notification #		Completed 09-30-1994		CO FF	
Subdivision Name						Lot #		Block #					
Well Constructor (Business Name) NIFFENEGGER, ED JR						Lic. # 135		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.6664 °N -89.5613 °W		Method Code GCD013	
Address 902 2ND ST MONROE WI 53566						Well Plan Approval #		NW NW Section Township Range or Govt Lot # 9 2 N 8 E		2. Well Type New Well			
Hicap Permanent Well #						Common Well #		Specific Capacity 2.2		Reason for replaced or reconstructed well ? WATER FOR NEW HOME			
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes						Hicap Property ? No		Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8.75 Surface 62			Rotary - Mud Circulation										
6 62 160			Yes Rotary - Air No										
			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ___ in. dia...										
			Dual Rotary										
			Temp. Outer Casing ___ in. dia										
			Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
- - I -			TOPSOIL			Surface			1				
- B L -			BROKEN LIMESTONE			1			4				
Y - L -			BUFF GALENA LIMESTONE			4			25				
U - L -			BLUE LIMESTONE			25			135				
- - N -			ST. PETER SANDSTONE			135			160				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STD. WT. ST..280 WALL 18.97# PER FT. PL END-WELDED JTS. USA SAWHILL A53B ASTM				Surface		62					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method PRESSURE													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT				Surface		62		15 S					
9. Static Water Level													
105.5 ft. below ground surface													
10. Pump Test													
Pumping level 110 ft. below surface													
Pumping at 10 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
NA													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
RN								11-20-1994					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	90	Building Overhang		10
			Septic or Holding, or POWTS Tank	>	30

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	WCR Submit Time	09/30/1994	REC'D WCR 1/21/14 W/NOTE: SANDY, FOUND THIS LOG TODAY IN OUR FILES. RANDY SAID TO SEND IT TO YOU.

Created On: 02-03-2014

Updated On: 01-21-2020

Review Status: