

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FX797		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner GELBACH CONSTRUCTION						Phone # (608)325-4660		1. Well Location				Fire # (if avail.)									
Mailing Address 1736 13TH ST						Town of SYLVESTER						N4087									
City MONROE						State WI		Zip Code 53566				Street Address or Road Name and Number DUTCH HOLLOW RD									
County Green		Co. Permit #		Notification #		Completed 09-08-1993		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) NIFFENEGGER, ED JR				Lic. # 135		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.6531 °N -89.5789 °W				Method Code GCD013							
Address 902 2ND ST MONROE WI 53566				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 17 2 N 8 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
Approval Date (mm-dd-yyyy)				Hicap Permanent Well # Common Well # Specific Capacity 3																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		62		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Yes		- B L -		BROKEN ROCK		Surface		6			
6		62		200						No		- - L -		GALENA-PLATTEVILLE		6		130			
												- - N -		ST PETER SANDSTONE		130		200			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		120 ft. below ground surface				12 in. above grade							
6		STD WT ST .280 WALL 18.97# PER FT PL END-WELDED JTS SAWHILL USA ASTM A53B				Surface		62		10. Pump Test Pumping level 125 ft. below surface Pumping at 15 GP for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method PRESSURE														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NA							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
NEAT CEMENT		Surface		62		15 S						13. Constructor / Supervisory Driller Lic # Date Signed RN 10-12-1993 Drill Rig Operator Lic or Reg # Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		6

Comment:

Created On: 04-13-2005

Updated On: 01-21-2020

Review Status: