Well Construction Report
WISCONSIN UNIQUE WELL NUMBER FX797

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GELBACH CONSTRUCTION			Phone #: (608)325-4660
Mailing Address: 1736 13TH ST			
City: MONROE	State: WI	Zip Code: 53566	
County: Green	Co. Permit #:	Notification #:	Completed: 09-08-1993

Well Constructor (Business Name): NIFFENEGGER, ED JR	Lic. #: 135	Facility ID # (Public Wells):	
Address: 902 2ND ST MONROE WI 53566		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SYLVESTER

Fire # (if avail.): N4087

Street Address or Road Name and Number: DUTCH HOLLOW RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 42.6531 °N -89.5789 °W				Method Code: GCD013
NE NW or Govt Lot #	Section: 17	Township: 2 N	Range: 8 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	62
6	62	200

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- No — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	B	L	-	BROKEN ROCK	Surface	6
-	-	L	-	GALENA-PLATTEVILLE	6	130
-	-	N	-	ST PETER SANDSTONE	130	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD WT ST .280 WALL 18.97# PER FT PL END-WELDED JTS SAWHILL USA ASTM A53B	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
120 ft. below ground surface

10. Pump Test
Pumping level 125 ft. below surface
Pumping at 15 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	62	15 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
RN		10-12-1993
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		6

Comment:

Created On: 04-13-2005 Updated On: 01-21-2020 Review Status: