

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				FX802		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PICK CONSTRUCTION, BLOUNT, KEN						Phone # (608)966-3450		1. Well Location				Fire # (if avail.)			
Mailing Address W8562 DAVIS RD						Town of SYLVESTER						N3963			
City BROWNTOWN						State WI		Zip Code 53522-				Street Address or Road Name and Number MEYER RD			
County Green		Co. Permit #		Notification #		Completed 10-26-1993		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) NIFFENEGGER, ED JR				Lic. # 135		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.6484 °N -89.5747 °W				Method Code GCD013	
Address 902 2ND ST MONROE WI 53566				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 17 2 N 8 E		2. Well Type New Well				of previous unique well #		constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		Reason for replaced or reconstructed well ? WATER FOR NEW HOME				Construction Type Drilled					
3. Well serves 1 # of				Hicap Well ? No		Reason for replaced or reconstructed well ? WATER FOR NEW HOME									
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?		Reason for replaced or reconstructed well ? WATER FOR NEW HOME				Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		63		Rotary - Mud Circulation				No					
6		63		120		Yes Rotary - Air				No					
Rotary - Air & Foam						Drill-Through Casing Hammer									
Reverse Rotary						Cable-tool Bit ___ in. dia...									
Dual Rotary						Temp. Outer Casing ___ in. dia									
Removed? ___ depth ft. (If NO explain on back side)						8. Geology									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		STD WT ST .280 WALL 18.97# PER FT PL END-WELDED JT USA SAWHILL A53B ASTM		Surface		63		- - I C		TOPSOIL & CLAY		Surface		3	
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)		- - B L		BROKEN LIMESTONE		3		8	
Y - L -		BUFF GALENA LIMESTONE		8		35		U - L -		BLUE PLATTEVILLE LIMESTONE		35		65	
- - N -		ST PETER SANDSTONE		65		120		9. Static Water Level							
60 ft. below ground surface								11. Well Is							
10. Pump Test								24 in. above grade							
Pumping level 75 ft. below surface								Developed ? Yes							
Pumping at 20 GP M for 2 Hrs.								Disinfected ? Yes							
Pumping Method ?								Capped ? Yes							
7. Grout or Other Sealing Material								12. Notified Owner of need to fill & seal ?							
Method PRESSURE								Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller							
NEAT CEMENT		Surface		63		15 S		Lic #							
Date Signed															
RN								11-29-1993							
Drill Rig Operator								Lic or Reg #							
Date Signed															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		10

Comment:

Created On: 10-03-2005

Updated On: 01-21-2020

Review Status: