Well Construction Report
WISCONSIN UNIQUE WELL NUMBER GF945

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GILBERTSON, LARRY			Phone #: (715)924-4784
Mailing Address: 884 WHITE ST			
City: CHETEK	State: WI	Zip Code: 54728	
County: Barron	Co. Permit #:	Notification #:	Completed: 10-25-1994

Well Constructor (Business Name): TERRY TIM OLSON	Lic. #: 4200	Facility ID # (Public Wells):	
Address: 834 LEINENKUGEL DR CHETEK WI 54728-9167		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #	Specific Capacity:	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of CHETEK

Fire # (if avail.): 00884

Street Address or Road Name and Number: 884 WHITE ST

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
NE NE or Govt Lot #	Section: 19	Township: 33 N	Range: 10 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD POINT PLUGGED

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	39

6. Casing, Liner, Screen — Removed? ____depth ft. (If NO explain on back side)

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	GALV	Surface	6
1.25	GALV	6	36
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	S S	36	39

7. Grout or Other Sealing Material
Method

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level _____ ft. below surface
Pumping at _____ GP for _____ Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TTO		11-20-1994
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Sewer - Building Sanitary		10
Building Overhang		2	Septic or Holding, or POWTS Tank		32

Comment:

Created On: 02-24-1995 Updated On: 02-24-1995 Review Status: