Well Construction Report
WISCONSIN UNIQUE WELL NUMBER GF977

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MORGAN, THEODORE M	Phone #: (715)837-1556
Mailing Address: PO BOX 2	
City: CHETEK	State: WI Zip Code: 54728
County: Barron	Co. Permit #:
Notification #	Completed: 11-04-1994
Well Constructor (Business Name): JEROME WOJTKIEWICZ	Lic. #: 561
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 1386 24 1/2 ST CAMERON WI 54822	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 7.5	

1. Well Location

Town of DALLAS	Fire # (if avail.): 548
Street Address or Road Name and Number: 548 18TH ST	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD): 45.2871 °N -91.7887 °W	Method Code: GCD013
NE SE or Govt Lot #:	Section: 1 Township: 32 N Range: 12 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	78
6	78	121

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	4
		H		SHALE	4	5
	S	N		SOFT SANDROCK	5	78
	H	N		SANDROCK HARD	78	121

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL PIPE PE 19 LBS FT PLUS 1 ASTMA 53BSAWHILL	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	78	24 S

9. Static Water Level
75 ft. below ground surface

10. Pump Test
Pumping level 77 ft. below surface
Pumping at 15 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		12-04-1993
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Building Overhang		30
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 01-24-1995 Updated On: 06-18-2020 Review Status: