

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				<b style="font-size: 1.2em;">GH232		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LINDALE DEVELOPMENT						Phone # (715)247-3079		1. Well Location				Fire # (if avail.)			
Mailing Address 964 192ND AVE						Town of SOMERSET						Street Address or Road Name and Number			
City NEW RICHMOND				State WI		Zip Code 54017									
County St. Croix		Co. Permit #		Notification #		Completed 10-21-1995		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) EDWIN A KALSTO				Lic. # 488		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code				
Address PO BOX 73 SOMERSET WI 54025-0073				Well Plan Approval #		SW		SW		Section 25		Township 31 N		Range 19 W	
				Approval Date (mm-dd-yyyy)		or Govt Lot #		2. Well Type New Well		of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Construction Type Drilled									
3. Well serves 1 # of HOME				Hicap Well ? No											
Private, potable				Hicap Property ? No											
Heat Exchange ____ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8		Surface		142		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
P				HARDPAN				Surface		30					
S				SAND				30		70					
P				HARDPAN				70		120					
S				SAND				120		142					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification				From (ft.)		To (ft.)							
4		T@C R@D ASTMA53 J SCH 40 X 21 IPSCO				Surface		138							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
2		JOHNSON CONT SLOT SS				138		142							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
11 LB BENTONITE CLAY SLURRY				Surface		138									
9. Static Water Level															
87 ft. below ground surface															
10. Pump Test															
Pumping level 112 ft. below surface															
Pumping at 10 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
EAK								Lic #		Date Signed 11-03-1995					
Drill Rig Operator								Lic or Reg #		Date Signed 11-03-1995					
GK															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Sewer - Building Sanitary		15
Building Overhang		10	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 12-05-1995

Updated On: 12-05-1995

Review Status: