

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				<b style="font-size: 1.2em;">GH236		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MONNOT, MARK						Phone # (715)269-5395		1. Well Location				Fire # (if avail.)							
Mailing Address PO BOX 37						Town of CYLON						Street Address or Road Name and Number							
City DEER PARK				State WI		Zip Code 54007													
County St. Croix		Co. Permit #		Notification #		Completed 10-24-1995		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) EDWIN A KALSTO				Lic. # 488		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address PO BOX 73 SOMERSET WI 54025-0073				Well Plan Approval #		SW NW		Section 5		Township 31 N		Range 16 W							
				Approval Date (mm-dd-yyyy)		or Govt Lot #		5		31 N		16 W							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		2. Well Type New Well													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # _____ constructed in _____											
						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ?		Reason for replaced or reconstructed well ? NEW HOME											
						Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole								Lower Open Bedrock					
10		Surface		20		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								8.75		20		137	
6		137		139										6		137		139	
8.75		20		137										6		137		139	
6		137		139										8.75		20		137	
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology									
6		PE ASTM A53 6 X SCH 40 X 21 SAWHILL				Surface		137											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		9. Static Water Level 92 ft. below ground surface									
6		PE ASTM A53 6 X SCH 40 X 21 SAWHILL				Surface		137											
7. Grout or Other Sealing Material										10. Pump Test									
Method										Pumping level 122 ft. below surface									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Pumping at 10 GP M for 3 Hrs.											
11 BENTONITE CL		Surface		137		137		Pumping Method ?											
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes										12. Notified Owner of need to fill & seal ?									
										Filled & Sealed Well(s) as needed?				No					
										NO OTHER WELL ON PROP				13. Constructor / Supervisory Driller					
										EAK				Lic #					
Drill Rig Operator				Lic or Reg #				Date Signed											
GK				11-18-1995				Date Signed											
11-18-1995				11-18-1995				11-18-1995											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		68	Sewer - Building Sanitary		25
Building Overhang		15	Septic or Holding, or POWTS Tank		58

Comment:

Created On: 12-22-1995

Updated On: 12-22-1995

Review Status: