

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				GI131		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner TOTAL SERVICE DEV Phone # (414)468-6220						1. Well Location				Fire # (if avail.)													
Mailing Address PO BOX 12206						Town of HOBART				Street Address or Road Name and Number 4170 CAMELOT													
City GREEN BAY				State WI		Zip Code 54307																	
County Brown		Co. Permit #		Notification #		Completed 05-14-1993		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) LEO VAN DE YACHT				Lic. # 31		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.5405 °N -88.1265 °W				Method Code GCD013											
Address 3383 OAK FOREST DR GREEN BAY WI 54313-7628				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 19 24 N 20 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOME															
				Approval Date (mm-dd-yyyy)		Construction Type Drilled																	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes																	
Hicap Well ? No Hicap Property ? No Hicap Potable ?		Hicap Well ? No Hicap Property ? No Hicap Potable ?																					
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
9		Surface		60		Yes Rotary - Mud Circulation Yes Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C CLAY P HARDPAN L LIMESTONE		Surface 55 55 60 60 262		55 60 60 262		55 60 60 262									
6		60		262																			
6		60		262																			
6		60		262																			
6		60		262																			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		25 ft. below ground surface				12 in. above grade									
6		NEW BLACK STEEL PLAIN END WELDED ASTM-A-53B, 18.97# PER FT. SAWHILL PIPE				Surface		60		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface Pumping at 25 GP M for 2 Hrs. Pumping Method ?													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?											
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement DRILL SLURRY Surface 60												Filled & Sealed Well(s) as needed? No N/APP											
DRILL SLURRY Surface 60												13. Constructor / Supervisory Driller				Lic #		Date Signed					
												LV				05-14-1993		Date Signed 05-14-1993					
												Drill Rig Operator				Lic or Reg #							
												TV				05-14-1993							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Collector Sewer - San or Storm		75
Clearwater Sump		30	Foundation Drain to Clearwater		17
			Sewer - Building Sanitary		35

Comment:

Created On: 06-09-1993

Updated On: 11-21-2019

Review Status: