

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				GM382		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SZUTA, WAYNE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 2347 S 34TH ST						City of MUSKEGO													
City MILWAUKEE						State WI		Zip Code 53215											
County Waukesha		Co. Permit #		Notification #		Completed 12-14-1993		Subdivision Name FOUNTAIN WOOD				Lot # Block #							
Well Constructor (Business Name) KENNETH J SWEENEY				Lic. # 583		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 11221 W ST MARTINS R FRANKLIN WI 53132-2331				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 1 5 N 20 E		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 2.5		Reason for replaced or reconstructed well ? NEW HOME													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		77.5						F I		FILL @ TOPSOIL		Surface		5			
						Rotary - Mud Circulation				C		CLAY		5		16			
						Rotary - Air				Y		SAND @ GRAVEL		16		24			
						Rotary - Air & Foam				C		CLAY		24		40			
						Drill-Through Casing Hammer				X G		CLAY, SAND, GRAVEL		40		70			
						Reverse Rotary				Y		SAND @ GRAVEL		70		75			
						Cable-tool Bit ___ in. dia...				G		GRAVEL		77		77.5			
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		32 ft. below ground surface				20 in. above grade					
6		18.45#/FT ASTM A53 SAWHILL WELDED				Surface		77.5		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface									
										Pumping at 20 GP M for 2 Hrs.									
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement #8 20 BENTONITE CRUMBLES MOUND AROUND SHOE AS DRIVEN Surface 0												Filled & Sealed Well(s) as needed?							
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												KJS						12-14-1993	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												KRS						12-14-1993	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		9	Foundation Drain to Clearwater		11
Clearwater Sump		19	Shoreline/Pool		100
Collector Sewer - San or Storm		123	Sewer - Building Sanitary		50

Comment:

Created On: 02-08-1994

Updated On: 02-08-1994

Review Status: