Well Construction Report
WISCONSIN UNIQUE WELL NUMBER GM382

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SZUTA, WAYNE	Phone #
Mailing Address: 2347 S 34TH ST	
City: MILWAUKEE	State: WI — Zip Code: 53215
County: Waukesha	Co. Permit #	Notification #	Completed: 12-14-1993

Well Constructor (Business Name): KENNETH J SWEENEY	Lic #: 583	Facility ID # (Public Wells)	
Address: 11221 W ST MARTINS R FRANKLIN WI 53132-2331		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 2.5	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
City of MUSKEGO

Fire # (if avail.)

Street Address or Road Name and Number: S66 W13432 SAROYAM RD

Subdivision Name	Lot #	Block #
FOUNTAIN WOOD		

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SW NE or Govt Lot #	Section	Township	Range
	1	5 N	20 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	77.5

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		F	I	FILL @ TOPSOIL	Surface	5
		C		CLAY	5	16
		Y		SAND @ GRAVEL	16	24
		C		CLAY	24	40
		X	G	CLAY, SAND, GRAVEL	40	70
		Y		SAND @ GRAVEL	70	75
		G		GRAVEL	77	77.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.45#/FT ASTM A53 SAWHILL WELDED	Surface	77.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 20 BENTONITE CRUMBLES MOUND AROUND SHOE AS DRIVEN	Surface	0	

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
KJS		12-14-1993
Drill Rig Operator	Lic or Reg #	Date Signed
KRS		12-14-1993

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		9	Foundation Drain to Clearwater		11
Clearwater Sump		19	Shoreline/Pool		100
Collector Sewer - San or Storm		123	Sewer - Building Sanitary		50

Comment:

Created On: 02-08-1994 Updated On: 02-08-1994 Review Status: