

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				GV930		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																
Property Owner WELFARE BUILDING AND LOAN ASSOC.						Phone #		1. Well Location				Fire # (if avail.)														
Mailing Address 2200 NORTH 3RD. STREET						Village of ELM GROVE						Street Address or Road Name and Number 12700 BLUEMOUND RD														
City MILWAUKEE				State WI		Zip Code 53012																				
County Waukesha		Co. Permit #		Notification #		Completed 01-01-1965		Subdivision Name			Lot #		Block #													
Well Constructor (Business Name) LAYNE CHRISTENSEN COMPANY				Lic. # 582		Facility ID # (Public Wells) 268082540		Latitude / Longitude in Decimal Degree (DD) <div style="display: flex; justify-content: space-around;"> °N °W </div>			Method Code GPS008															
Address 6005 W. MARTIN DR MILWAUKEE WI				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 25 7 N 20 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																		
				Approval Date (mm-dd-yyyy)																						
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4																						
3. Well serves # of Non-community				Hicap Well ? No		Hicap Property ? No																				
Heat Exchange # of drillholes				Hicap Potable ?																						
4. Potential Contamination Sources - ON REVERSE SIDE																										
5. Drillhole Dimensions and Construction Method												8. Geology														
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)											
10 Surface 15			No Rotary - Mud Circulation No						C CLAY			Surface 10														
9.725 15 50			No Rotary - Air No						B C L BROKEN LIMESTONE AND CLAY			10 15														
6 50 358			No Rotary - Air & Foam No						L CREVICED LIMESTONE			15 30														
			No Drill-Through Casing Hammer						L SOLID LIMESTONE			30 350														
			No Reverse Rotary						X L H LIMESTONE W/ SHALE			350 358														
			No Cable-tool Bit ____in. dia... No																							
			Dual Rotary																							
			No Temp. Outer Casing ____in. dia																							
			No Removed? ____depth ft. (If NO explain on back side)																							
6. Casing, Liner, Screen												9. Static Water Level						11. Well Is								
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)			To (ft.)			36 ft. below ground surface						36 in. above grade					
10 STEEL			Surface						15			Pumping level 148 ft. below surface						Developed ? Yes								
6 STEEL			15						50			Pumping at 42 GP for 3 Hrs.						Disinfected ? Yes								
Dia. (in.)			Screen type, material & slot size						From (ft.)			To (ft.)			Pumping Method ?						Capped ? Yes					
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?														
Method												Filled & Sealed Well(s) as needed? No														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller						Lic #		Date Signed								
NEAT CEMENT				Surface		50				Drill Rig Operator						Lic or Reg #		Date Signed								

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 10-01-2003

Created by: PARRIG

Updated On: 04-19-2013

Updated by: PWS TRANSFER