

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HD761		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner SIESS, RICHARD						Phone # (608)372-4656		1. Well Location				Fire # (if avail.)											
Mailing Address 30092 HONEYSUCKLE AV						Village of OAKDALE						30092											
City CAMP DOUGLAS						State WI		Zip Code 54618				Street Address or Road Name and Number HONEYSUCKLE AVE											
County Monroe		Co. Permit #		Notification #		Completed 05-30-2000		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) JIM PARKHURST JR				Lic. # 320		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.9318 °N -90.39 °W				Method Code GCD013											
Address 28700 OTTOMAN AV ELROY WI 53929-9801				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW NW Section Township Range or Govt Lot # 21 17 N 1 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
Hicap Permanent Well #		Common Well #		Specific Capacity 4		Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes																							
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		33		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ___ in. dia... No Dual Rotary Yes Temp. Outer Casing 10in. dia Yes Removed? ___ depth ft. (If NO explain on back side)						T - S C		CLAY & BROWN SAND		Surface		12					
6		33		115								I H N -		HARD WHITE SAND ROCK		12		115					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		60 ft. below ground surface				12 in. above grade									
6		NEW STEEL 18.97 SAWHILL A53 WELDED				Surface		33		10. Pump Test Pumping level 62 ft. below surface Pumping at 8 GP M for 12 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)															
7. Grout or Other Sealing Material Method PUMPED														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
NEAT CEMENT				Surface		33		12 S															
														13. Constructor / Supervisory Driller				Lic #		Date Signed			
														JP								05-30-2000	
														Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		10
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 03-14-2002

Updated On: 04-29-2020

Review Status: