Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HD963

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KING, DALE			Phone #
Mailing Address: 210 N WALES RD			
City: WALES	State: WI	Zip Code: 53183	
County: Waukesha	Co. Permit #	Notification #	Completed: 03-28-1996

Well Constructor (Business Name): DARYL BUTCH GIBOUR	Lic #: 17	Facility ID # (Public Wells)	
Address: 7482 CIRCLE DR LANNON WI 53046		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.9	

3. Well serves 1 # of BUILDING
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GENESSE

Fire # (if avail.)

Street Address or Road Name and Number: 210 N WALES RD

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
NW SW or Govt Lot #:	Section: 4	Township: 6 N	Range: 18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW BUILDING

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	90

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	S	SANDY CLAY	Surface	14
		Y		SAND @ GRAVEL	14	43
		C	G	CLAY @ STONES	43	65
		L		LIMESTONE	65	90

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B B E SAWHILL	Surface	65
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	0	

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 38 ft. below surface
Pumping at 15 GP M for 12 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BG		04-01-1996
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	500
Building Overhang		15

Type	Qualifier	Distance
Buried Petroleum Tank		189
Septic or Holding, or POWTS Tank		89

Comment:

Created On: 05-03-1996 Updated On: 05-03-1996 Review Status: