

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HD965		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BORKENHAGEN, GEORGE					Phone #			1. Well Location				Fire # (if avail.)			
Mailing Address W220 N7460 CHERRY HI					Town of RICHFIELD							Street Address or Road Name and Number 4603 ELMWOOD RD			
City SUSSEX			State WI		Zip Code 53089										
County Washington		Co. Permit #		Notification #			Completed 04-12-1996		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) DARYL BUTCH GIBOUR				Lic. # 17		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2201 °N -88.2642 °W				Method Code GCD013	
Address 7482 CIRCLE DR LANNON WI 53046				Well Plan Approval #				NE NE		Section 29		Township 9 N		Range 19 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #		29		9 N		19 E	
Hicap Permanent Well #			Common Well #			Specific Capacity				2. Well Type New Well					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				of previous unique well #				constructed in			
								Reason for replaced or reconstructed well ?							
								Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		335		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Y				SAND @ GRAVEL				Surface		78					
Z S				SANDY CLAY @ STONES				78		241					
Y				SAND @ GRAVEL				241		263					
Z				CLAY @ GRAVEL				263		319					
Y				SAND @ GRAVEL				319		335					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		ASTM A53B B E SAWHILL				Surface		335							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface		0									
9. Static Water Level															
150 ft. below ground surface															
10. Pump Test															
Pumping level 150 ft. below surface															
Pumping at 10 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
BG				Lic #				Date Signed							
BG								04-15-1996							
Drill Rig Operator				Lic or Reg #				Date Signed							
BG															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Collector Sewer - San or Storm		17
Building Overhang		15	Septic or Holding, or POWTS Tank		130

Comment:

Created On: 05-16-1996

Updated On: 07-05-2019

Review Status: