Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HD966

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EHRENDRIECH, DALE	Phone #
Mailing Address: W317 S2968 ROBERTS N	
City: WAUKESHA	State: WI — Zip Code: 53188
County: Waukesha	Co. Permit #	Notification #	Completed: 04-18-1996
Well Constructor (Business Name): DARYL BUTCH GIBOUR	Lic. #: 17	Facility ID # (Public Wells)
Address: 7482 CIRCLE DR LANNON WI 53046	Well Plan Approval #
	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 5

1. Well Location

Town of GENESEE

Fire # (if avail.)

Street Address or Road Name and Number: W317 S2968 ROBERTS CT N

Subdivision Name	Lot #	Block #
ESSER POINT 2		

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code

NE	SW	Section	Township	Range
or Govt Lot #		9	6 N	18 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of HOMES

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	85

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	CLAY @ GRAVEL	Surface	9
Y	SAND @ GRAVEL	9	63
C	CLAY	63	75
L	LIMESTONE	75	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B BE SAWHILL	Surface	75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

32 ft. below ground surface

10. Pump Test

Pumping level 34 ft. below surface

Pumping at 10 GP M for 12 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	0	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BG		04-18-1996
Drill Rig Operator	Lic or Reg #	Date Signed
BG		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90
Building Overhang		20

Type	Qualifier	Distance
Clearwater Sump		41
Wastewater Sump		38
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 06-04-1996 Updated On: 06-04-1996 Review Status: