

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HJ400		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SEVERIN, NORMAN						Phone # (218)398-6022		1. Well Location				Fire # (if avail.)			
Mailing Address 4142 S CTY TK E						City of SUPERIOR						Street Address or Road Name and Number			
City SOUTH RANGE						State WI		Zip Code 54874				6104 E 3RD ST HWY E			
County Douglas		Co. Permit #		Notification #		Completed 12-03-1993		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) MILTON H LONG				Lic. # 279		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.6665 °N -92.0015 °W				Method Code GCD013	
Address PO BOX 355 POPLAR WI 54864-0355				Well Plan Approval #				NW SE		Section 4		Township 48 N		Range 13 W	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well					
Reason for replaced or reconstructed well ?				NEW HOME											
3. Well serves 1 # of				Hicap Well ? No				Construction Type Drilled							
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 190			Yes Rotary - Mud Circulation												
6 190 260			Rotary - Air												
			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit ___ in. dia...												
			Dual Rotary												
			Temp. Outer Casing ___ in. dia												
			Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)						
C G			CLAY @ BOULDER						Surface 190						
N			SAND STONE						190 260						
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)									
6		A53 BLACK				Surface		190							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)									
7. Grout or Other Sealing Material															
Method PUMP															
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement											
DRILL MUD		Surface 190													
9. Static Water Level															
90 ft. below ground surface															
10. Pump Test															
Pumping level 220 ft. below surface															
Pumping at 5 GP M for 6 Hrs.															
Pumping Method ?															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
NONE															
13. Constructor / Supervisory Driller				Lic #				Date Signed							
MHL															
Drill Rig Operator				Lic or Reg #				Date Signed							
WK															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Septic or Holding, or POWTS Tank		90

Comment:

Created On: 02-09-1996

Updated On: 06-25-2020

Review Status: