Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HJ666

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WITTHUHN, BARRY			Phone #: (414)757-0492
Mailing Address: N1350 HIGHGREEN DR			
City: GREENVILLE	State: WI	Zip Code: 54942	
County: Outagamie	Co. Permit #:	Notification #:	Completed: 03-02-1994

Well Constructor (Business Name): TIPLER WELL @ PUMP	Lic. #: 55	Facility ID # (Public Wells):	
Address: PO BOX 34 LAKEWOOD WI 54138-0034		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GREENVILLE

Fire # (if avail.):

Street Address or Road Name and Number: N1350 HIGHGREEN DR

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.2896 °N -88.525 °W
Method Code: GCD013

SW	SE	Section	Township	Range
or Govt Lot #		14	21 N	16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	58
6	58	143

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Yes Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	50
P	HARDPAN	50	57
L	LIMESTONE	57	100
N	SANDSTONE	100	143

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR. B SAWHILL TUBULAR WELDED JOINT WT.18.97 PER FT.	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	58	

9. Static Water Level
60 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 30 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
AT		03-14-1994
Drill Rig Operator	Lic or Reg #	Date Signed
AT		03-14-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Collector Sewer - San or Storm		100

Comment:

Created On: 06-01-1994 Updated On: 11-20-2019 Review Status: