

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HJ970		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner GARFIELD, ROBERT						Phone # (414)849-4824		1. Well Location				Fire # (if avail.)	
Mailing Address 200 DOVE LN						Town of BASS LAKE							
City CHILTON						State WI		Zip Code 53014					
County Sawyer		Co. Permit #		Notification #		Completed 11-15-1993		Subdivision Name				Lot #	Block #
Well Constructor (Business Name) ROSCOE C BUTTERFIELD				Lic. # 357	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code		
Address RT 3 HAYWARD WI 54843-9803				Well Plan Approval #		NE	SE	Section 6	Township 39 N	Range 8 W			
Hicap Permanent Well #				Common Well #		Specific Capacity 6.5		2. Well Type New Well				of previous unique well # constructed in	
Reason for replaced or reconstructed well ? WATER FOR NEW HOME				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ?									
3. Well serves 1 # of Private, potable													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock						
4	Surface	83	Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)							
4	NEW BLACK STEEL, WELDED 10.79#/FT ASTM A-53BSAWHILL				Surface	79							
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)							
4	STAINLESS STEEL				79	83							
7. Grout or Other Sealing Material Method GRAVITY													
Kind of Sealing Material				From (ft.)	To (ft.)	# Sacks Cement							
BENTONITE				Surface	0								
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
A	Y	G	SAND, GRAVEL, COARSE GRAVEL		Surface		15						
S	G	SAND, GRAVEL		15		42							
W	S	SAND, WATER		42		83							
9. Static Water Level													
42 ft. below ground surface													
10. Pump Test													
Pumping level 44 ft. below surface													
Pumping at 13 GP M for 1 Hrs.													
Pumping Method ?													
11. Well Is													
27 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?												No	
NONE													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
RB										12-16-1993			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		84	Building Overhang		108
			Septic or Holding, or POWTS Tank		99

Comment:

Created On: 01-31-1994

Updated On: 01-31-1994

Review Status: