Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HJ971

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOEMER, PAT @ DIANNE			Phone #: (612)481-8202
Mailing Address: 4025 EVERGREEN PL			
City: SHOREVIEW	State: MN	Zip Code: 55126	
County: Burnett	Co. Permit #:	Notification #:	Completed: 11-15-1993

Well Constructor (Business Name): ROSCOE C BUTTERFIELD	Lic. #: 357	Facility ID # (Public Wells):	
Address: RT 3 HAYWARD WI 54843-9803		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of WEBB LAKE
Street Address or Road Name and Number

Fire # (if avail.)

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD) °N °W | Method Code

NE	NE	Section	Township	Range
or Govt Lot #		30	41 N	14 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER FOR NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	158

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Air .....
Rotary - Mud Circulation .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	40
		X	M	SAND, CLAY, SILT SAND	40	66
	W	Y		SAND, GRAVEL, WATER	66	95
		M	S	SILT SAND	95	120
	A	C	G	CLAY, COARSE GRAVEL	120	140
	W	Y		SAND, GRAVEL, WATER	140	158

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL, WELDED 10.79#/FT ASTM A-53 BSAWHILL	Surface	154
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	154	158

7. Grout or Other Sealing Material
Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	0	

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 23 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		12-17-1993
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		51	Building Overhang		75
			Septic or Holding, or POWTS Tank		57

Comment:

Created On: 02-08-1994 Updated On: 02-08-1994 Review Status: