

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HJ971		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BOEMER, PAT @ DIANNE						Phone # (612)481-8202		1. Well Location				Fire # (if avail.)									
Mailing Address 4025 EVERGREEN PL						Town of WEBB LAKE															
City SHOREVIEW						State MN		Zip Code 55126													
County Burnett		Co. Permit #		Notification #		Completed 11-15-1993		Subdivision Name				Lot #									
								Block #													
Well Constructor (Business Name) ROSCOE C BUTTERFIELD				Lic. # 357		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address RT 3 HAYWARD WI 54843-9803				Well Plan Approval #		NE NE		Section 30		Township 41 N		Range 14 W									
						or Govt Lot #															
Approval Date (mm-dd-yyyy)				Heat Exchange ___ # of drillholes		Hicap Well ? No		Hicap Property ? No		Hicap Potable ?		2. Well Type New Well									
Hicap Permanent Well #		Common Well #		Specific Capacity 5		Reason for replaced or reconstructed well ? WATER FOR NEW HOME		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
4		Surface		158		Rotary - Mud Circulation				S		SAND		Surface		40					
						Yes Rotary - Air				X M		SAND, CLAY, SILT SAND		40		66					
						Rotary - Air & Foam				W Y		SAND, GRAVEL, WATER		66		95					
						Drill-Through Casing Hammer				M S		SILT SAND		95		120					
						Reverse Rotary				A C G		CLAY, COARSE GRAVEL		120		140					
						Cable-tool Bit ___ in. dia...				W Y		SAND, GRAVEL, WATER		140		158					
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				24 in. above grade							
4		NEW BLACK STEEL, WELDED 10.79#/FT ASTM A-53 BSAWHILL				Surface		154		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 23 ft. below surface				Disinfected ? Yes							
4		STAINLESS STEEL				154		158		Pumping at 15 GP M for 1 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method GRAVITY														Filled & Sealed Well(s) as needed? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		NONE											
BENTONITE				Surface		0															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														RB						12-17-1993	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		51	Building Overhang		75
			Septic or Holding, or POWTS Tank		57

Comment:

Created On: 02-08-1994

Updated On: 02-08-1994

Review Status: