Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HJ972

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MOLLERUS, MICHAEL			Phone #: (612)941-2906
Mailing Address: 6311 DORON LN			
City: EDINA	State: MN	Zip Code: 55435	
County: Barron	Co. Permit #:	Notification #:	Completed: 11-18-1993

Well Constructor (Business Name): ROSCOE C BUTTERFIELD	Lic. #: 357	Facility ID # (Public Wells):	
Address: RT 3 HAYWARD WI 54843-9803		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.4	

1. Well Location

Town of CEDAR LAKE

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW SW or Govt Lot #:	Section: 23	Township: 36 N	Range: 10 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: WATER FOR NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	122

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Y	C		SAND, GRAVEL, CLAY	Surface	40
W	Y			SAND, GRAVEL, WATER	40	60
W	Y	C		SAND, GRAVE, CLAY, ROCKS, WATER	60	80
	X			SAND, CLAY	80	100
W	Y	C		SAND, GRAVEL, CLAY, WATER	100	122

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL, WELDED 10.97#/FT ASTM A53 BSAWHILL	Surface	118
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	118	122

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	0	

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 18 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		12-17-1993
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		9
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 02-08-1994 Updated On: 02-08-1994 Review Status: