

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HK181		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner V & B INVESTMENT						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 2750 BAILEY RD						Town of SUN PRAIRIE							
City SUN PRAIRIE						State WI		Zip Code 53590					
County Dane		Co. Permit # 11402		Notification #		Completed 12-12-1995		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) PHILLIP HASTINGS				Lic. # 4464		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address HASTINGS WELL DRLG & SERV INC DEERFIELD WI 53531				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 17 8 N 11 E		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?							
3. Well serves 2 # of Private, potable				Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Property ? No		Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
8.75		Surface		92		Yes Rotary - Mud Circulation		No		Geology Codes			
6		92		120		Rotary - Air				Type, Caving/Noncaving, Color, Hardness, etc...			
						Rotary - Air & Foam				From (ft.) To (ft.)			
						Drill-Through Casing Hammer				K C - - BLACK CLAY Surface 12			
						Reverse Rotary				T - Z - BROWN CLAY, GRAVEL 12 15			
						Cable-tool Bit ___ in. dia...				T - Z S BROWN CLAY, GRAVEL, SAND 15 46			
						Dual Rotary				R - Z S RED CLAY, GRAVEL, SAND 46 63			
						Temp. Outer Casing ___ in. dia				G - Z S GRAY CLAY, GRAVEL, SAND 63 92			
						Removed? ___ depth ft. (If NO explain on back side)				Y N - - YELLOW SANDSTONE 92 120			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		ASTM A53 BLACK STEEL SAWHILL WELD				Surface		91		36 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
										12 in. above grade			
7. Grout or Other Sealing Material										10. Pump Test			
Method										Pumping level ___ ft. below surface			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Pumping at ___ GP for ___ Hrs.		Developed ? Yes			
MUD & CUTTINGS		Surface		91				Pumping Method ?		Disinfected ? Yes			
Filled & Sealed Well(s) as needed?										Capped ? Yes			
12. Notified Owner of need to fill & seal ?										13. Constructor / Supervisory Driller			
Filled & Sealed Well(s) as needed?										Lic #			
Date Signed										Date Signed			
PH										01-05-1996			
Drill Rig Operator										Lic or Reg #			
Date Signed										Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Downspout/Yard Hydrant	>	10
Building Drain - Sanitary	>	8	Landfill	>	1200
Building Overhang	>	3	Septic or Holding, or POWTS Tank	>	25

Comment: NO CHANGES WERE EVER MADE TO WCR AFTER BEING SENT BACK MANY TIMES.

Created On: 10-23-2006

Updated On: 11-02-2006

Review Status: