

<b>Well Construction Report</b> <b>WISCONSIN UNIQUE WELL NUMBER</b>				<b>HN298</b>		<b>Drinking Water and Groundwater - DG/5</b> <b>Department of Natural Resources, Box 7921</b> <b>Madison WI 53707</b>				Form 3300-077A									
Property Owner RYE, TERRY						Phone # (715)276-6772		<b>1. Well Location</b>				Fire # (if avail.)							
Mailing Address 16704 NICOLET RD						Town of TOWNSEND						Street Address or Road Name and Number							
City TOWNSEND				State WI		Zip Code 54175													
County Oconto		Co. Permit #		Notification #		Completed 01-16-1995		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) TIPLER WELL DRILLING INC				Lic. # 55		Facility ID # (Public Wells) 443063830		Latitude / Longitude in Decimal Degree (DD) 45.32745 °N -88.59657 °W			Method Code GPS008								
Address PO BOX 34 LAKEWOOD WI 54138-0034				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 22 33 N 15 E		<b>2. Well Type</b> Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? REPLACED SANDPOINT											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8		Construction Type Drilled													
<b>3. Well serves</b> 1 # of TAVERN Non-community				Hicap Well ? No Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
<b>4. Potential Contamination Sources - ON REVERSE SIDE</b>																			
<b>5. Drillhole Dimensions and Construction Method</b>												<b>8. Geology</b>							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		68		Yes Rotary - Mud Circulation ..... Yes Rotary - Air ..... Rotary - Air & Foam ..... Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary ..... Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Y		SAND GRAVEL		Surface		72					
<b>6. Casing, Liner, Screen</b>						<b>9. Static Water Level</b>				<b>11. Well Is</b>									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				12 in. above grade					
6		ASTM A53 GR B SAWHILL TUBULAR WELDED JOINT WT18 97 PER FT				Surface		68		<b>10. Pump Test</b> Pumping level 55 ft. below surface Pumping at 12 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
4		10 SLOT STAINLESS				68		72		<b>12. Notified Owner of need to fill &amp; seal ?</b> Filled & Sealed Well(s) as needed?									
<b>7. Grout or Other Sealing Material</b>						Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement DRILLING MUD Surface 68													
<b>13. Constructor / Supervisory Driller</b>						Lic #		Date Signed											
						AT		02-01-1995											
						Drill Rig Operator		Lic or Reg #		Date Signed									
						AT				02-01-1995									

**4a. Potential Contamination Sources**Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		10
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 06-22-1995

Created by: HFRC LOAD

Updated On: 08-19-2022

Updated by: FILBEJ