Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HN308

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MORY, ROBERT	Phone #: (414)833-2571
Mailing Address: 233 W HICKORY	
City: SEYMOUR	State: WI — Zip Code: 54165
County: Oconto	Co. Permit #: — Notification #: — Completed: 03-14-1994
Well Constructor (Business Name): TIPLER WELL @ PUMP	Lic. #: 55 — Facility ID # (Public Wells):
Address: PO BOX 34 LAKEWOOD WI 54138-0034	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1

1. Well Location

Town of RIVERVIEW

Fire # (if avail.):

Street Address or Road Name and Number: 16077 CURRIE LA

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 45.2599 °N -88.5552 °W — Method Code: GCD013

NW or Govt Lot #	NW	Section	Township	Range
		18	32 N	16 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: REPLACED SANDPOINT

Construction Type: Drilled

3. Well serves 1 # of COTTAGE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	43
6	43	46

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Yes Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND, GRAVEL	Surface	5
		S		SAND	5	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A 53 GR. B SAWHILL TUBULAR WELDED JOINT WT.18.97 PER FT.	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	10 SLOT SANDSCREEN	43	46

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	43	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
AT		03-24-1994
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AT		03-24-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		5
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 07-07-1994 Updated On: 11-15-2019 Review Status: