Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HN310

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GESELL, KATHY	Phone #: (715)276-2203
Mailing Address: 17286 THIELKE RD	
City: LAKEWOOD	State: WI Zip Code: 54138
County: Oconto	Co. Permit #:
Notification #	Completed: 03-22-1994
Well Constructor (Business Name): TIPLER WELL @ PUMP	Lic. #: 55
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: PO BOX 34 LAKEWOOD WI 54138-0034	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 1	

1. Well Location

Town of LAKEWOOD

Fire # (if avail.)

Street Address or Road Name and Number: 17286 THIELKE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.304 °N -88.4749 °W	GCD013

SW SE or Govt Lot #	Section	Township	Range
	34	33 N	16 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: REPLACED SANDPOINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	59
6	59	63

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Yes Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	10
		G	G	GRAVEL, BOULDERS	10	25
		S		SAND	25	63

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A 53 GR. B SAWHILL TUBULAR WELDED JOIN WT.18.97 PER FT.	Surface	59
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	10 SLOT STAINLESS SCREEN	59	63

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 10 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	59	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
AT		03-24-1994
Drill Rig Operator	Lic or Reg #	Date Signed
AT		03-24-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		10
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 07-07-1994 Updated On: 11-15-2019 Review Status: