Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HN401

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WELCH, MYRTLE	Phone #
Mailing Address: W1852 W TOWNHALL RD	
City: GRESHAM	State: WI — Zip Code: 54128
County: Shawano	Co. Permit #	Notification #	Completed: 05-04-1994

Well Constructor (Business Name): DANIEL DILLENBURG	Lic. #: 196	Facility ID # (Public Wells)
Address: RT 3 BOX 247 SHAWANO WI 54166-9803		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 3.2

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of RED SPRINGS

Fire # (if avail.)

Street Address or Road Name and Number
TOWNHALL RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W — Method Code

SW	SE	Section	Township	Range
or Govt Lot #		20	28 N	14 E

2. Well Type Replacement
of previous unique well # constructed in 94

Reason for replaced or reconstructed well ?
POINT WELL DRY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	65

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Yes Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	S	SANDY CLAY	Surface	12
		C		CLAY	12	29
		S		SAND	29	36
		C		CLAY	36	50
		S		SAND	50	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	AST M A53 1897 SAWHILL WELDED	Surface	61
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS STEEL 15 SLOT	61	65

7. Grout or Other Sealing Material
Method CIRCULATION

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	61	

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 46 ft. below surface
Pumping at 35 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DD		07-14-1994
Drill Rig Operator	Lic or Reg #	Date Signed
		07-14-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		89	Building Overhang		25
			Septic or Holding, or POWTS Tank		61

Comment:

Created On: 02-06-1995 Updated On: 02-06-1995 Review Status: