Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HN728

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CARLINO, JIM	Phone #: (715)877-2737
Mailing Address: 1569 GRAVEL PIT RD	
City: AUGUSTA	State: WI — Zip Code: 54722
County: Eau Claire	Co. Permit #: W10332 — Notification # — Completed: 05-11-1994
Well Constructor (Business Name): PAUL H WEBSTER	Lic. #: 156 — Facility ID # (Public Wells)
Address: 6608 PRUNE LAKE RD RHINELANDER WI 54501-9173	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 0.7

1. Well Location

Town of WASHINGTON				Fire # (if avail.): 1414
Street Address or Road Name and Number: PARTRIDGE RD				
Subdivision Name: PHEASANT RUN			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.8035 °N -91.3654 °W				Method Code: GCD013
SW SW or Govt Lot #	Section: 21	Township: 27 N	Range: 8 W	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?: BUILDING NEW HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	53

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		F		BLACK DIRT	Surface	1
		S		SAND	1	38
	S	N	C	SOFT SAND STONE CLAY	38	45
	S	N		SOFT SAND STONE	45	53

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	A53 GRADE B A 536.625K 280 BVD # W452 40992SAWHILL	Surface	49
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	JOHNSON STAINLESS #10	49	53

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 10 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJB		05-11-1994
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50
Building Drain - Sanitary	>	10
Building Overhang		15
Sewer - Building Sanitary	>	10
Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 08-11-1994 Updated On: 08-01-2019 Review Status: