

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HN728		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner CARLINO, JIM						Phone # (715)877-2737		1. Well Location				Fire # (if avail.) 1414							
Mailing Address 1569 GRAVEL PIT RD						Town of WASHINGTON						Street Address or Road Name and Number PARTRIDGE RD							
City AUGUSTA			State WI		Zip Code 54722		Subdivision Name PHEASANT RUN				Lot # 		Block # 						
County Eau Claire		Co. Permit # W10332		Notification # 		Completed 05-11-1994		Latitude / Longitude in Decimal Degree (DD) 44.8035 °N -91.3654 °W				Method Code GCD013							
Well Constructor (Business Name) PAUL H WEBSTER				Lic. # 156		Facility ID # (Public Wells) 		SW SW Section Township Range or Govt Lot # 21 27 N 8 W		2. Well Type New Well									
Address 6608 PRUNE LAKE RD RHINELANDER WI 54501-9173				Well Plan Approval # 		Approval Date (mm-dd-yyyy) 		of previous unique well # constructed in											
Hicap Permanent Well # 			Common Well # 		Specific Capacity 0.7		Reason for replaced or reconstructed well ? BUILDING NEW HOME												
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) 6		From (ft.) Surface		To (ft.) 53		Upper Enlarged Drillhole 		Lower Open Bedrock 		Geology Codes 		Type, Caving/Noncaving, Color, Hardness, etc... 		From (ft.) 		To (ft.) 			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)						F BLACK DIRT Surface 1 S SAND 1 38 S N C SOFT SAND STONE CLAY 38 45 S N SOFT SAND STONE 45 53							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.) 6.625		Material, Weight, Specification Manufacturer & Method of Assembly A53 GRADE B A 536.625K 280 BVD # W452 40992SAWHILL				From (ft.) Surface		To (ft.) 49		25 ft. below ground surface				14 in. above grade					
Dia. (in.) 3		Screen type, material & slot size JOHNSON STAINLESS #10				From (ft.) 49		To (ft.) 53		10. Pump Test Pumping level 40 ft. below surface Pumping at 10 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material Method 												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller EJB								Lic # 		Date Signed 05-11-1994									
Drill Rig Operator 								Lic or Reg # 		Date Signed 									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Building Overhang		15
Building Drain - Sanitary	>	10	Sewer - Building Sanitary	>	10
			Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 08-11-1994

Updated On: 08-01-2019

Review Status: