Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HP449

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHNSTON, JOSEPH			Phone #: (715)537-3254
Mailing Address: 1441 14 1/2 AVE			
City: BARRON	State: WI	Zip Code: 54812	
County: Barron	Co. Permit #:	Notification #:	Completed: 06-14-1994

Well Constructor (Business Name): JEROME WOJTKIEWICZ	Lic. #: 561	Facility ID # (Public Wells):	
Address: 1386 24 1/2 ST CAMERON WI 54822		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 8	

1. Well Location

Town of CEDAR LAKE

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: RED CEDAR LAKE SHORES	Lot #: 6	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:

SW NE or Govt Lot #:	Section: 11	Township: 36 N	Range: 10 W	

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	50

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND @ GRAVEL	Surface	3
		G		GRAVEL	3	24
		S		SAND	24	29
		Y		SAND @ GRAVEL	29	36
	N	S		FINE SAND	36	40
	A	S		COARSE SAND	40	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 19LB/FT ASTM A53B SAWHILL	Surface	47
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL CONT SLOT	47	50

7. Grout or Other Sealing Material

Method AS CASING IS DRVEN

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	3	

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 32.5 ft. below surface

Pumping at 20 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

17 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
JW		06-14-1994
Drill Rig Operator	Lic or Reg #	Date Signed
SW		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Shoreline/Pool		90
			Septic or Holding, or POWTS Tank		72

Comment:

Created On: 10-13-1994 Updated On: 10-13-1994 Review Status: