Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HP457

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MORLEY, MARLIN	Phone #: (715)234-1015
Mailing Address: 1869 S WISCONSIN AVE	
City: RICE LAKE	State: WI — Zip Code: 54868
County: Barron	Co. Permit #: — Notification #: — Completed: 07-05-1994
Well Constructor (Business Name): JEROME WOJTKIEWICZ	Lic. #: 561 — Facility ID # (Public Wells):
Address: 1386 24 1/2 ST, CAMERON WI 54822	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2

1. Well Location

City of RICE LAKE — Fire # (if avail.):

Street Address or Road Name and Number: 877 WEST AVE

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW SW or Govt Lot # — Section: 17 — Township: 35 N — Range: 11 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of COMMERCIAL BLDG

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	302

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	1
		G		GRAVEL	1	12
		Z		CLAY GRAVEL	12	76
T		C		CLAY BROWN	76	88
		Z		GRAVEL @ CLAY	88	124
		S		SAND	124	128
		G		GRAVEL	128	148
		Z		CLAY @ GRAVEL	148	196
		Y		SAND @ GRAVEL DIRTY	196	204
		Z		CLAY @ GRAVEL	204	245
Y		S		YELLOW SAND	245	270
		N		SANDSTONE	270	302

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL P E ASTM A53B SAWHILL USA 19 LB FT	Surface	272
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE AS CASING	Surface	0	
DRIVEN			6 S

9. Static Water Level	11. Well Is
131 ft. below ground surface	15 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 138.5 ft. below surface	Disinfected ? Yes
Pumping at 15 GP M for 3 Hrs.	Capped ? Yes
Pumping Method ?	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
SW		07-08-1994
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		28	Collector Sewer - San or Storm		60
Building Overhang		7	Wastewater Sump		25
			Sewer - Building Sanitary		28

Comment:

Created On: 01-20-1995 Updated On: 10-08-2012 Review Status: