

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HR062		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner BOYDA, BOB						Phone # (906)779-1771		1. Well Location				Fire # (if avail.)											
Mailing Address N3071 LK ANTOINE RD						Town of AURORA																	
City IRON MOUNTAIN						State MI		Zip Code 49801															
County Florence		Co. Permit #		Notification #		Completed 10-07-1994		Street Address or Road Name and Number VAN REMOORTERE LN															
						Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) DARYL NEUENS				Lic. # 6053		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code											
						Well Plan Approval #		NW NW Section Township Range or Govt Lot # 15 38 N 19 E															
Address RT 1 BOX 36 NIAGARA WI 54151						Approval Date (mm-dd-yyyy)		2. Well Type New Well															
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4		of previous unique well # constructed in															
3. Well serves 1 # of Private, potable						Hicap Well ? No		Reason for replaced or reconstructed well ?															
Heat Exchange ___ # of drillholes						Hicap Property ? No																	
						Hicap Potable ?		Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		30										C		CLAY		Surface		25			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										S		MED SAND		25		28	
																Y		SAND @ GRAVEL		28		30	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		14 ft. below ground surface				20 in. above grade									
6		A53 BLK STL SAWHILL USA 1897 LB FT 280 IN WALL				Surface		26		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 25 ft. below surface													
6		NM COOK NO 304 ST ST BB WW FIG K PKR 18 SLOT				26		30		Pumping at 4 GP M for 0.5 Hrs.													
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method KEPT FULL GRAN BENTONITE WHILE																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?													
GRANULAR BENTONITE				Surface		26		3 S		NA													
														13. Constructor / Supervisory Driller				Lic #		Date Signed			
														DN						10-10-1994			
														Drill Rig Operator				Lic or Reg #		Date Signed			
														DN						10-10-1994			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Other Contamination Sources	<	1000
			Septic or Holding, or POWTS Tank		125

Comment:

Created On: 02-06-1995

Updated On: 02-06-1995

Review Status: