Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HR062

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOYDA, BOB			Phone #: (906)779-1771
Mailing Address: N3071 LK ANTOINE RD			
City: IRON MOUNTAIN	State: MI	Zip Code: 49801	
County: Florence	Co. Permit #:	Notification #:	Completed: 10-07-1994

Well Constructor (Business Name): DARYL NEUENS	Lic. #: 6053	Facility ID # (Public Wells):	
Address: RT 1 BOX 36 NIAGARA WI 54151		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of AURORA

Fire # (if avail.):

Street Address or Road Name and Number: VAN REMOORTERE LN

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NW or Govt Lot #	Section: 15	Township: 38 N	Range: 19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	30

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	25
S	MED SAND	25	28
Y	SAND @ GRAVEL	28	30

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 BLK STL SAWHILL USA 1897 LB FT 280 IN WALL	Surface	26
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	NM COOK NO 304 ST ST BB WW FIG K PKR 18 SLOT	26	30

7. Grout or Other Sealing Material

Method KEPT FULL GRAN BENTONITE WHILE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	26	3 S

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 4 GP M for 0.5 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
DN		10-10-1994
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DN		10-10-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150

Type	Qualifier	Distance
Other Contamination Sources	<	1000
Septic or Holding, or POWTS Tank		125

Comment:

Created On: 02-06-1995 Updated On: 02-06-1995 Review Status: