Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HR064

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCULATI, MARV			Phone #: (319)332-6330
Mailing Address: 3885 ASBURY			
City: BENTTENDORF	State: IA	Zip Code: 52722	
County: Florence	Co. Permit #:	Notification #:	Completed: 10-25-1994

Well Constructor (Business Name): DARYL NEUENS	Lic. #: 6053	Facility ID # (Public Wells):	
Address: RT 1 BOX 36 NIAGARA WI 54151		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of FLORENCE
Fire # (if avail.)
Street Address or Road Name and Number: CARPENTER RD
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code

NE	SW	Section	Township	Range
or Govt Lot #		23	40 N	19 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
WATER FOR NEW HOME
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	51

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND @ GRAVEL	Surface	18
		S		MED @ COARSE SAND	18	42
		Y		MED @Q COARSE SAND WITH GRAVEL	42	51

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 BLK STL SAWHILL USA 1897 LB FT 280 IN WALL	Surface	49
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
	COOK NO 304 ST ST WWBB FIG K PKT 3 FT 20 SLOT	48	51

7. Grout or Other Sealing Material
Method KEPT FULL GRAN BENTONITE WHEN

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	0.5	0.2 S

9. Static Water Level
29 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 20 GP M for 0.5 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
DN		10-26-1994
Drill Rig Operator	Lic or Reg #	Date Signed
DN		10-26-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Shoreline/Pool		150
Building Overhang		10	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-28-1995 Updated On: 03-28-1995 Review Status: