Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HR065

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANDERSON, STEVE	Phone #: (414)336-2881
Mailing Address: N6037 COUNTY LINE RD	
City: DE PERE	State: WI — Zip Code: 54115
County: Marinette	Co. Permit #: — Notification #: — Completed: 10-28-1994
Well Constructor (Business Name): DARYL NEUENS	Lic. #: 6053 — Facility ID # (Public Wells):
Address: RT 1 BOX 36 NIAGARA WI 54151	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of GOODMAN

Fire # (if avail.):

Street Address or Road Name and Number: WOOD LK RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SE NW or Govt Lot #: — Section: 10 — Township: 36 N — Range: 17 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW CAMP

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	89

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	Y		SAND @ GRAVEL CAVING	Surface	25
		Y	G	SAND GRAVEL @ COBBLE	25	68
	A	Y		COARSE SAND @ GRAVEL	68	80
		Y		SAND @ GRAVEL	80	89

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 BLK STL SAWHILL USA 280 IN WALL 1897 LB FT	Surface	88.25
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	NM ST STL BBWW FIG K PKR 3 FT 20 SLOT COOK 304	86	89

7. Grout or Other Sealing Material

Method: KEPT FULL GRAN BENTONITE WHEN

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	88	7

9. Static Water Level

65 ft. below ground surface

10. Pump Test

Pumping level 84 ft. below surface

Pumping at 6 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
DN		10-31-1994
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DN		10-31-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 03-28-1995 Updated On: 03-28-1995 Review Status: