Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HS333

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NASH, TERRY			Phone #: (608)582-2013
Mailing Address: 600 S 15TH			
City: GALESVILLE	State: WI	Zip Code: 54630	
County: Trempealeau	Co. Permit #:	Notification #:	Completed: 09-22-1994

Well Constructor (Business Name): CARL F SCHULTZ	Lic. #: 365	Facility ID # (Public Wells):	
Address: 29 E 10TH ST BUFFALO COCHRANE WI 54622-7335		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 15	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GALE

Fire # (if avail.):

Street Address or Road Name and Number: ENGEN RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NW NW or Govt Lot #	Section: 6	Township: 18 N	Range: 8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME BEING BUILT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	8
4	8	94

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		SAND CAVING BROWN FINE SOFT	Surface	94

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BL STEEL T@C A53B E 11.00# IPSCO	Surface	91
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
3.75	STAINLESS STEEL 12 SLOT	91	94

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CUTTINGS	Surface	8	

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 51 ft. below surface
Pumping at 15 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE TO SEAL

13. Constructor / Supervisory Driller	Lic #	Date Signed
CFS		09-06-1994
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CFS		09-06-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75
Building Drain - Sanitary		10
Building Overhang		9
Sewer - Building Sanitary		75
Septic or Holding, or POWTS Tank	>	75

Comment:

Created On: 10-28-1994 Updated On: 10-28-1994 Review Status: