

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HS337		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner PASSOW, WILBERT						Phone # (608)685-4522		1. Well Location				Fire # (if avail.)							
Mailing Address S2865 MAPLE RD						Town of MELTON						Street Address or Road Name and Number MAPLE RD							
City FOUNTAIN CITY				State WI		Zip Code 54629													
County Buffalo		Co. Permit #		Notification #		Completed 09-20-1994		Subdivision Name PINE CREST				Lot #		Block #					
Well Constructor (Business Name) CARL F SCHULTZ				Lic. # 365		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address 29 E 10TH ST BUFFALO COCHRANE WI 54622-7335				Well Plan Approval #				NE SW		Section 25		Township 20 N		Range 12 W					
				Approval Date (mm-dd-yyyy)				or Govt Lot #		Township 20 N		Range 12 W							
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				Reason for replaced or reconstructed well ? NEW HOME BEING BUILT											
								Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock									
8		Surface		8		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)				4				8		67			
8. Geology																			
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)						To (ft.)		V S		SAND NONCAV BROWN SOFT		Surface		6	
Q S		SAND CAV BROWN SOFT		6						67									
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly								From (ft.)		To (ft.)		9. Static Water Level					
4		NEW BL STEEL T@C A53BE 11.00# IPSCO				Surface		63		45 ft. below ground surface									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test									
3.75		STAINLESS STEEL 12 SLOT				63		67		Pumping level 45 ft. below surface									
7. Grout or Other Sealing Material										Pumping at 15 GP M for 4 Hrs.									
Method										Pumping Method ?									
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is											
PUDDLED CUTTINGS		Surface		8				14 in. above grade											
										Developed ? Yes									
										Disinfected ? Yes									
										Capped ? Yes									
12. Notified Owner of need to fill & seal ?										Filled & Sealed Well(s) as needed? NONE TO SEAL									
13. Constructor / Supervisory Driller								Lic #		Date Signed									
CFS										09-22-1994									
Drill Rig Operator								Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 12-08-1994

Updated On: 12-08-1994

Review Status: