Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HS338

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WICKA, DON	Phone #: (608)248-2666
Mailing Address: 2575 N RIVER RD	
City: BUFFALO CITY	State: WI — Zip Code: 54622
County: Buffalo	Co. Permit #: — Notification #: — Completed: 10-05-1994
Well Constructor (Business Name): CARL F SCHULTZ	Lic. #: 365 — Facility ID # (Public Wells):
Address: 29 E 10TH ST BUFFALO COCHRANE WI 54622-7335	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity:	

1. Well Location

City of BUFFALO CITY

Fire # (if avail.):

Street Address or Road Name and Number: 2575 N RIVER RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

or Govt Lot #	NW	NW	Section	Township	Range
			6	20 N	12 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: SANDPOINT FAILING

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	8
4	8	50

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		SAND CAVING BROWN SOFT	Surface	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BL STEEL T@C A53BE 11.00# IPSCO	Surface	47
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
3.75	STAINLESS STEEL 15 SLOT	47	50

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CUTTINGS	Surface	8	

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 18 GP M for 5 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

PUMP INSTALLER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
CFS		10-07-1994
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		56
Building Drain - Sanitary		48
Building Overhang		4
Sewer - Building Sanitary		48
Septic or Holding, or POWTS Tank		51

Comment:

Created On: 12-08-1994 Updated On: 12-08-1994 Review Status: